

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-1586:100 Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Star Pipe Products, 4018 Westhollow Parkway, Houston, TX 77082  
Contact: Mark Bowsher (281) 558-3000 Fax (281) 368-5369\*

**DESIGN:** Models GBV-3 (2 ½– 10) indicating butterfly valves. Sizes from 2 ½, 3" outside diameter, 3", 4", 5", 6", 8" and 10" NPS. 10" NPS is for valves with modification only. Models GBV-3 valves have supervisory switch. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Working pressure: 175 psi GBV-3 (10")  
300 psi GBV-3 (2 ½ 8")

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Sizes 2 ½ – 8" for indoor/outdoor service. Size 10" for indoor service only.

**MARKING:** Listee's name, model number, rating and UL/FM label.

**APPROVAL:** Listed as indicating butterfly valves for use with fire sprinkler systems.

**XLF:** 7770-1243:101

\*Rev. 07-03-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 3, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager